

WELL COMPLETION REPORT

3/71

CROTON FALLS

PUTNAM COUNTY DEPARTMENT OF HEALTH

Division of Environmental Health Services

COUNTY OFFICE BUILDING - CARMEL, NEW YORK

This report is to be completed by well driller and submitted to County Health Department together with laboratory report of analysis of water sample indicating water is of satisfactory bacterial quality before certificate of construction compliance is issued.

REPORT MUST BE SUBMITTED WITHIN 30 DAYS OF WELL COMPLETION

41220 73 41 05

P1015

OWNER	NAME Robert Hansen		ADDRESS Box 432, Croton Falls, NY 10519	
LOCATION OF WELL	(No. & Street) Cherry Hill Lane		(Town) Carmel, NY	(Lot Number)
PROPOSED USE OF WELL	<input checked="" type="checkbox"/> DOMESTIC <input type="checkbox"/> BUSINESS ESTABLISHMENT <input type="checkbox"/> FARM <input type="checkbox"/> TEST WELL <input type="checkbox"/> PUBLIC SUPPLY <input type="checkbox"/> INDUSTRIAL <input type="checkbox"/> AIR CONDITIONING <input type="checkbox"/> OTHER (Specify)			
DRILLING EQUIPMENT	<input checked="" type="checkbox"/> ROTARY <input type="checkbox"/> COMPRESSED AIR PERCUSSION <input type="checkbox"/> CABLE PERCUSSION <input type="checkbox"/> OTHER (Specify)			
CASING DETAILS	LENGTH (feet) 85'	DIAMETER (Inches) 6"	WEIGHT PER FOOT 19 lbs.	<input checked="" type="checkbox"/> THREADED <input type="checkbox"/> WELDED <input checked="" type="checkbox"/> DRIVE SHOE YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> WAS CASING GROUTED? YES <input type="checkbox"/> NO
YIELD TEST	<input type="checkbox"/> BAILED <input checked="" type="checkbox"/> PUMPED <input type="checkbox"/> COMPRESSED AIR		HOURS 6	G.P.M. 15
WATER LEVEL	MEASURE FROM LAND SURFACE - STATIC (Specify feet) 22'		DURING YIELD TEST (feet) 230'	
SCREEN DETAILS	MAKE			LENGTH OPEN TO AQUIFER (feet)
	SLOT SIZE	DIAMETER (Inches)	IF GRAVEL PACKED:	GRAVEL SIZE (Inches) FROM (feet) TO (feet)

DEPTH FROM LAND SURFACE FEET to FEET		FORMATION DESCRIPTION
0	70	Drilling in overburden clay and boulders
		Hit rock at 70 feet
70	85	Drilling in rock, set casing, grouted.
85	230	Drilling in rock granite.

Sketch exact location of well with distances, to at least two permanent landmarks.

RECEIVED

JUL 29 1983

PUTNAM COUNTY
DEPT. OF HEALTH

If yield was tested at different depths during drilling, list below

FEET	GALLONS PER MINUTE

DATE WELL COMPLETED 1/17/83	DATE OF REPORT 4/22/83	WELL DRILLER (Signature)
--------------------------------	---------------------------	------------------------------

P. F. Beal & Sons, Inc.